04

## GOVERNMENT OF WEST BENGAL OFFICE OF THE DIVISIONAL FIRE OFFICER WEST BENGAL FIRE & EMERGENCY SERVICES G.T. Road, Bosepara, Mahesh-1, P.S. - Serampore, Pin 712202

Memo No: IND/WB/FES/20192020/80326 DATE: 24/02/2020

From:

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To:

EDUCARE INTERNATIONAL SCHOOL
RATANPUR BESIDE DURGAPUR HIGHWAY,POST & P.S-SINGUR,DIST-H00GHLY.
Serampur F.S., Singur,
Hooghly - 712409.

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 4 storied building under group Educational at the premises no.- RATANPUR BESIDE DURGAPUR HIGHWAY, POST & P.S-SINGUR, DIST-H00GHLY., Singur, Hooghly - 712409

This is in reference to your Application No. IND/WB/FES/20192020/80326,dated 24/02/2020, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 4 storied building under group Educational at the premises no.- RATANPUR BESIDE DURGAPUR HIGHWAY,POST & P.S-SINGUR,DIST-H00GHLY., Singur, Hooghly - 712409.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.

- 2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- 3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
- 5. Electrical safety audit to be conducted positively by 31 st March o f every year.
- 6. A fire control room including a closed circuit T.V. system will have to be installed which observes entire of the buildings.
- 7. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
- 8. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- 9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 10. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
- 11.A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
- 12. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
- 14. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 15. Periodical flashing of water in the Hydrants shall be made to maintain the efficiency

working performance of above mention system.

16. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire

Prevention maintenance register.

17.All the electrical cable should be paint by fire stop paint to check the spread of fire.

18.If anything happens for improper life safety measure in the building within this period then

school authority will be responsible for that.

19.Stand by pump, u.g.w.r and the rest incomplete job as per recommendation issued from

fire service end to be done within ninety days after getting the renewal fsc

20. The renewal of fire safety certificate is valid for three years and has to be renewed every

three year from the date of issue of this letter.

21. Each after three years a certificate is to be obtained from the Divisional Fire Officer,

Hooghly Divn, West Bengal Fire & Emergency Services performance of all the life & Fire

Safety arrangements and installations of the building.

**Divisional Fire Officer** West Bengal Fire & Emergency Services

Signature Not Verified Digitally signed by SANAT KUMAR MONDAL Date: 2020.02.24 15:20:44 IST